



TYPICAL ELEVATION VIEW FOR
FHR & FIRE EXTINGUISHERS
NTS




FFL
TYPICAL ELEVATION VIEW OF FIRE EXTINGUISHERS
NOT COMBINED WITH FIRE HOSE REELS



FIRE EXTINGUISHERS (FE)
FIXING DETAIL
NTS

5 LEGEND

- 1) FHR ---- Fire Horse Reel
- 2) Z ---- 9Kg pressurised water fire extinguisher
- 3) Y  ---- 9Kg dry powder fire extinguisher
- 4) X ---- 9Kg Co₂ fire extinguisher
- 5) P3 ---- Duty Roof fire pump
- 6) P4 ---- Stand-By Roof booster fire pump


(1) FIRE HOSE WATER TANK PUMP DETAILS(P3 & P4)

PUMPING CAPACITY – 6L/S

HEAD = 10 m

POWER RATING -2.2KW ,3 ϕ ,50HZ

INCLUDING ASSOCIATED DRAWINGS

[illegible]

ELECTRICAL AND MECHANICAL
CONSULTING ENGINEERS

TAFARA BUILDING, SUITE C5
60 G. SILUNDIKA/FIFTH STREET
HARARE
TELEPHONE : 793995
TEL/FAX : 793996
CELL : 011 705 360
091 369 662
Email : tabo-tech@comone



ZIMBABWE
ASSOCIATION
Lace
CONSULTING
ENGINEERS

MINISTRY

©COPYRIGHT TABO-TECH

THIS DRAWING IS A PROPERTY OF TABO-TECH AND
SHALL NOT BE COPIED, TRACED, PHOTOGRAPHED OR
REPRODUCED IN ANY MANNER WHATSOEVER WITHOUT PRIOR
WRITTEN PERMISSION OF TABO-TECH CONSULTING ENGINEERS.

ARCHITECT:-

MANYARA DESIGN ARCHITECTS

CLIENT:-

ZIMBABWE REVENUE AUTHORITY

PROJECT:-

ZIMRA CORPORATE HEAD OFFICE

DRAWING DESCRIPTION:-

ROOF GENERAL FIRE PROTECTION

SCALE	1:100	DATE	OCT 2020
DESIGNED	R.B	DATE	OCT 2020
DRAWN	RH	DATE	OCT 2020
CHECKED	R.B	DATE	OCT 2020
APPROVED	R.B	DATE	OCT 2020

PROJECT & DRAWING No.

46/M

REVISION