


# **STANDARD BIDDING DOCUMENT FOR**

## **THE PROCUREMENT OF GOODS**

### **DOMESTIC TENDER**

**ZIMRA NCB 40/2021**



**ZIMRA**  
Zimbabwe Revenue Authority

**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PROCUREMENT REFERENCE NUMBER: DOMESTIC TENDER ZIMRA NCB 40/2021**


**PROCURING ENTITY: ZIMBABWE REVENUE AUTHORITY**

**DATE OF ISSUE: 08 October 2021**

**CLOSING DATE: 15 November, 2021**

**SITE MEETING DATES**

<b>MT SELINDA</b>	<b>2 November 2021 @0900 hours</b>
<b>MASVINGO</b>	<b>3 November 2021 @0900 hours</b>
<b>MLAHLANDELA</b>	<b>4 November 2021 @0900 hours</b>
<b>MPHOENG'S BORDER</b>	<b>5 November 2021 @0900 hours</b>
<b>KARIBA BORDER</b>	<b>22 October 2021 @0900 hours</b>
<b>CENTRAL STORES (HARARE)</b>	<b>29 October 2021 @0900 hours</b>
<b>ZB CENTRE (HARARE)</b>	<b>29 October 2021 @1100 hours</b>



**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**


**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**Table of Contents**

**Part 1: Bidding Procedures**

**Part 2: Statement of Requirements**

**Part 3: Contract**



# **BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

## **PART 1 BIDDING PROCEDURES**

### **PART 1: BIDDING PROCEDURES**

#### **References:**

References to the Act are to the Public Procurement and Disposal of Public Assets Act [Chapter 22:23] and references to the Regulations are to the Public Procurement and Disposal of Public Assets (General) Regulations (Statutory Instrument No. 5 of 2018). The terms and requirements in the Act and Regulations govern the submission of Bids and should be read by all Bidders.

**Procurement Reference Number: DOMESTIC TENDER ZIMRA NCB 40/2021**

#### **Preparation of Bids**

You are requested to bid for the Supply and Delivery of Toner Cartridges as specified in the Statement of Requirements below, by completing and returning the following documentation:

1. the Bid Submission Sheet in this Part;
2. the Statement of Requirements in Part 2;
3. a copy of every document necessary to demonstrate eligibility in terms of section 28 (1) of the Regulations;
4. Proof of supplier registration with the Procurement Regulatory Authority of Zimbabwe (PRAZ).
5. A bid security
6. A copy of CR 14, CR6 ( CR5 and CR6) and a Certificate of Incorporation or equivalent documents (foreign companies should submit similar company documents from country of company registration)
7. A valid tax clearance (ITF 263) for Zimbabwean or equivalent.
8. Company profile
9. At least three (3) reference letters showing bidders' direct experience in the successful provision of similar services being sought.
10. A valid proof of NSSA registration


#### **Number of bids allowed**

No Bidder may submit more than one bid, either individually or as a joint venture partner in another Bid, except as a subcontractor. Where the procurement is divided into lots and packages, only one Bid can be submitted. A conflict of interest will be deemed to arise if bids are received from more than one Bidder owned, directly or indirectly, by the same person.

#### **Clarification**

Clarification of the bidding document may be requested in writing by any Bidder and should be sent to;

**The Director Procurement  
Zimbabwe Revenue Authority (ZIMRA)  
10<sup>th</sup> Floor, ZB Centre  
Corner Kwame Nkrumah Ave/ First Street  
Harare, Zimbabwe.**



# **BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

## **PART 1 BIDDING PROCEDURES**

Or via Email to [procurement@zimra.co.zw](mailto:procurement@zimra.co.zw)

Such queries should be submitted within 10 days from the date of publication and responses to questions / queries will be made in writing to all prospective bidders at least 5 days before tender closing.

### **Site meeting**

**There shall be site meeting for this tender**

### **Validity of Bids**

The minimum period for which the Bidder's bid must remain valid is 90 days from the deadline for the submission of bids.


### **Submission of Bids**

Bids must be submitted in writing in a sealed envelope to the address below, no later than the date and time of the deadline below. It is the Bidder's responsibility to ensure that they receive a receipt confirming submission of their bid that has correct details of the Bidder and the number of the Bid.

The Bidder must mark the envelope with the Bidder's name and address and the Procurement Reference Number.

Bids should be submitted in triplicate with one (1) original copy marked "ORIGINAL" and two (2) copies each marked "COPY". All 3 copies should be in sealed envelopes clearly marked with the details of the tender, and should be deposited in a tender box situated at the below address. In the event of any discrepancy between the original and the copies, the original will prevail.

Late bids will be rejected. The Procuring Entity reserves the right to extend the bid submission deadline but will notify all potential bidders who have collected the bidding documents of the amended bid submission deadline.



Date of deadline: **15 November 2021**

Deadline Time: **1000Hours  
CAT**

Submission address: **Zimbabwe Revenue Authority  
6<sup>th</sup> Floor, ZB Centre  
Corner Kwame Nkrumah Ave/ First Street  
Harare; Zimbabwe**

Means of acceptance: Bids in the sealed envelopes shall be deposited in a tender box situated at the above address. All the bidders should record their bids in the tender submission register situated thereto, in the format prescribed in the register.

### **Bid opening**

**Due to the Covid 19 pandemic, NO Bidders will be allowed to witness the opening of bids on the closing day.**

# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

---

### Withdrawal, amendment or modification of Bids

A Bidder may withdraw, substitute, or modify its Bid after it has been submitted by sending a written notice, duly signed by an authorized representative. However, no Bid may be withdrawn, substituted, or modified in the interval between the deadline for submission of Bids and the expiration of the period of Bid validity specified by the Bidder or any extension of that period.

### Delivery Requirements

The delivery period required (from the date of contract signing) and the final destination for delivery are as indicated in the Delivery Schedule in Part 2.

### Bid Prices and Discounts

The prices and discounts quoted by the Bidder in the Bid Submission Form and in the Price Schedules must conform to the requirements specified below.

Prices must be quoted as specified in the Price Schedule included in Part 2 Statement of Requirements. In quoting prices, the Bidder is free to use transportation through carriers registered in any eligible country and similarly may obtain insurance services from any eligible country. Prices quoted must include the following costs and components:

- (a) For Goods
  - (i) the price of the Goods and the cost of delivery to the final destination, including the relevant INCOTERM, as stated in the Delivery Schedule;
  - (ii) the custom duties to be paid on the Goods on entry in Zimbabwe, if not already included;
  - (iii) Any other applicable import taxes;
  - (iv) Any sales and other taxes due within Zimbabwe which will be payable on the Goods if not already included;
  - (v) Any rebate or mark-up of the local agent or representative.
- (b) for Related Services, (other than inland transportation and other services required to convey the Goods to their final destination), whenever such Related Services are specified in the Schedule of Requirements:

the price of each item comprising the Related Services (inclusive of any applicable taxes).

### Bid Security

The Bidder must include Bid Security of ZWS 150,000.00 in *either* of the following forms;


**Option 1 ----- A certified Bank Cheque in the ZIMRA name.**

**Option 2 -----A Bank Guarantee in the ZIMRA name**

**Option 3 ----- A Cash Deposit to the Authority PRAZ**

The bid security shall be valid for a period of 90 days after the end of the bidding period.

Any bid not accompanied by a Bid Security where this is a requirement of bidding, will be rejected by the Procuring Entity as non-responsive.



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

If a bidder chooses options 2 or 3, the following should be noted;

### Option 2

#### Submission of bank guarantee

A standard bank Guarantee of **ZWS 150,000.00** which is valid for 90 days, obtainable from a reputable Registered Commercial Bank redeemable in **Zimbabwe**.

Please note: The required Bank Guarantee should include the following features and be redeemable in Zimbabwe in order for it to be considered valid:

1. Letterhead of registered commercial bank (i.e. the Supplier of the Bank Guarantee
2. The Header has to clearly state that it is a Bank Guarantee.
3. Purpose of the Bank Guarantee to be clearly stated.
4. The date when the Common Seal of the said Surety was effected should be clearly shown.
5. Conditions of the said Obligations must be stated.
6. The physical address of the Surety should be given.
7. The validity period of the Bank Guarantee must be clearly stated.
8. Signature of surety and the date when it was endorsed must be clearly shown.
9. It must be an original document that is date stamped.
10. Bid Bonds from Insurance Companies are not acceptable.
11. All foreign Bank Guarantee to be confirmed by a local corresponding Commercial bank in Zimbabwe.


The Bank Guarantee of the unsuccessful bidders will be released immediately after the award of the Tender while that of the winning bidder will only be released after submission of Performance Bond as specified in the tender document section 1.9

### Option 3

If **Option 3** is chosen bidders must pay **ZWS 150,000.00** for the Bid Security that shall be **Refundable at the end of the bid validity period plus another ZWS\$28,000.00** that shall be non-refundable for cash bid bond establishment fee in line with Part IV of the Procurement Regulations (S.I.5 of 2018). The amount is payable at Procurement Regulatory Authority of Zimbabwe (PRAZ), 76 Samora Machel Avenue, Harare or to be deposited into the following Account numbers:

#### 1. NON-REFUNDABLE (LOCAL)

BANK NAME:	COMMERCIAL BANK OF ZIMBABWE
ACCOUNT NAME:	PROCUREMENT REGULATORY AUTHORITY OF ZIMBABWE
ACCOUNT NUMBER:	01121064850020
BRANCH:	KWAME NKRUMAH



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

### 2. REFUNDABLE (LOCAL)

BANK NAME: COMMERCIAL BANK OF ZIMBABWE  
ACCOUNT NAME: PROCUREMENT REGULATORY AUTHORITY OF ZIMBABWE  
ACCOUNT NUMBER: 01121064850030  
BRANCH: KWAME NKRUMAH

The Bid Security of a Joint Venture (JV) must be in the name of the JV that submits the Bid. If the JV has not been legally constituted at the time of bidding, the Bid Security must be in the names of all intended partners

### Evaluation of Bids

Bids will be evaluated using the following methodology:

1. Preliminary examination to confirm that all documents required have been provided, to confirm the eligibility of Bidders in terms of section 28 (1) of the Regulations and to confirm that the Bid is administratively compliant in terms of section 28 (2) of the Regulations.
2. Technical evaluation to determine substantial responsiveness to the specifications in the Statement of Requirements;
3. Financial evaluation and comparison to determine the evaluated price of bids and to determine the lowest evaluated bid.

**Bids failing any stage will be eliminated and not considered in subsequent stages.**

### Review by the Special Procurement Oversight Committee

Section 54 of the Act provides for review by the Special Procurement Oversight Committee for certain especially sensitive or especially valuable contracts. This requirement will be subject to this review, hence, at least two identical copies of the bid document are required. Where the copies are not identical, the contents of the bid marked original will alone be considered. Bidders are required to pay administration fee of **ZW\$ 8000.00** for contracts subject to review by the Special Procurement Oversight Committee.

### Evaluation criteria

#### 1. Administrative Evaluation

Evaluation Parameter	Compliant / Non-Compliant
1. Bid Validity Must be 90 days.	
2. Bid Security of ZW\$150,000.00	
3. Proof of registration with the Procurement Regulatory Authority of Zimbabwe (2021).	
4. Valid Tax Clearance Certificate.	



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

5. Proof of registration with NSSA.	
6. Bidders must provide a minimum of three (3) references in form of <b>reference letters on client letterhead</b> showing direct experience on similar projects.	
7. Bidders must submit a signed bid submission sheet .	
8. Bidders Should state payment Terms <b>and abide to those terms.</b>	
9. Delivery Period must be stated. Preferably shorter delivery period.	
10. Company Profile with, Certificate of Incorporation, CR6 now CR5 and CR14 now CR6 or other company registration documents.	
11. Warranty (At least 1 year)	

### 2. Technical Evaluation

Technical evaluation shall be done using the technical specification and compliance sheet attached.


### 3. Financial Evaluation.

This shall be done using the prices submitted by bidders.

### Eligibility and Qualification Criteria

Bidders are required to meet the criteria in section 28 of the Act to be eligible to participate in public procurement and to be qualified for the proposed contract. They must therefore provide any available documentation and certify their eligibility in the Bid Submission Sheet. To be eligible, Bidders must

1. have the legal capacity to enter into a contract;
2. not be insolvent, in receivership, bankrupt or being wound up, not have had business activities suspended and not be the subject of legal proceedings for any of these circumstances;
3. have fulfilled their obligations to pay taxes and social security contributions in Zimbabwe



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

---

4. not have a conflict of interest in relation to this procurement requirement;
5. not be debarred from participation in public procurement under section 72 (6) of the Act and section 74(1) (c), (d) or (e) of the Regulations or declared ineligible under section 99 of the Act;
6. have the nationality of an eligible country as specified in the Special Conditions of Contract; and
7. have been registered with the Authority as a Supplier and have paid the applicable Supplier Registration Fee set out in Part III of the Fifth Schedule to the Regulations.

### Origin of Goods

All goods and related services must have as their country of origin an eligible country, as specified in the Special Conditions of Contract.

### Technical Criteria

The Technical Specifications Sheet details the minimum specification of the goods required. The goods offered must meet this specification, but no credit will be given for exceeding the specification. No alternatives to technical specifications given shall be accepted for evaluation.

### Currency

According to SI 185/2020, Bids should be priced in United States Dollars (US\$) and Zimbabwean Dollar (ZWL). Payment of the contract will be made at the prevailing interbank rate.

### Award of Contract

The bid, after application of any additional evaluation criteria, including any margin of preference, which is substantially responsive to the requirements of this bidding document will be recommended for award of contract. The proposed award of contract will be by issue of a Notification of Contract Award in terms of section 55 of the Act which will be effective until signature of the contract documents in accordance with Part 3: Contract. Unsuccessful Bidders will receive the Notification of Contract Award and, if they consider they have suffered prejudice from the process, they may within 14 days of receiving this Notification, submit to the Procuring Entity a Challenge in terms of section 73 of the Act, subject to payment of the applicable fee set out in section 44 of and the Third Schedule to the Regulations.

The contract will only be valid subject to payment of annual contract administration fee which is determined when the bid is deemed successful.


### Right to Reject

The Procuring Entity reserves the right to accept or reject any Bids or to cancel the procurement process and reject all Bids at any time prior to contract award.

### Corrupt Practices

The Government of Zimbabwe requires that Procuring Entities, as well as Bidders and Contractors, observe the highest standard of ethics during the procurement and execution of contracts. In pursuit of this policy:

1. the Procuring Entity will reject a recommendation for award if it determines that the Bidder recommended for award has, directly or through an agent, engaged in corrupt, fraudulent, collusive or coercive practices in competing for the Contract or been declared ineligible to be awarded a procurement contract under section 99 of the Act;
2. the Authority may under section 72 (6) of the Act impose the sanctions under section 74 (1) of the Regulations; and




**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMBABWE NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

3. Any conflict of interest on the part of the Bidder must be declared.



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 1 BIDDING PROCEDURES

### Bid Submission Sheet

*{Note to Bidders: Complete this form with all the requested details and submit it as the first page of your Bid. Attach the completed Statement of Requirements and any other documents requested in Part 1. Ensure that your Bid is authorised in the signature block below. A signature and authorisation on this form will confirm that the terms and conditions of this Bid prevail over any attachments. If your Bid is not authorised, it may be rejected. If the Bidder is a Joint Venture (JV), the Bid must be signed by an authorized representative of the JV on behalf of the JV, and so as to be legally binding on all the members as evidenced by a power of attorney signed by their legally authorized representatives.}*

*Bidders must mark as "CONFIDENTIAL" information in their Bids which is confidential to their business. This may include proprietary information, trade secrets or commercial or financially sensitive information}.*

Procurement Reference Number:

Subject of Procurement:

Name of Bidder:

Bidder's Reference Number:

Date of Bid:

We offer to supply the items listed in the attached Statement of Requirements, at the prices indicated on the attached Price Schedule and in accordance with the terms and conditions stated in your Bidding Document referenced above.

We confirm that we meet the eligibility criteria specified in Part 1: Procedures of Bidding.


We declare that we are not debarred from bidding and that the documents we submit are true and correct.

The validity period of our bid is: ..... {days} from the date of submission.

We confirm that the prices quoted in the attached Price Schedule are fixed and firm for the duration of the validity period and will not be subject to revision, variation or adjustment.

**Bid Authorised by:**

Signature .....	Name: .....
Position: .....	Date: .....(DD/MM/YY)
Authorised for and on behalf of:	
Company .....	
Address: .....	
.....	



**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

**PART 2 STATEMENT OF REQUIREMENTS**

**PART 2: STATEMENT OF REQUIREMENTS**

Name of Bidder:

Bidder's Reference Number:

**List of Goods and Price Schedule**

Currency of Bid: ...US\$/ZWL.....

**BIDDING DOCUMENT FOR THE SUPPLY AND DELIVERY OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

Lot No	Description of Goods	Quantity <sup>2</sup>	Unit Price <sup>3</sup> US\$/ZWL\$	Total Price <sup>4</sup> US\$/ZWL\$
			[to be provided by the Bidder]	[to be provided by the Bidder]
Lot 1	300 KVA Generator for ZB Centre as per attached specifications.	1		
Lot 1	15 KVA Generator for Central Stores as per attached specifications.	1		
Lot 1	60 KVA Generator for Kariba Border Post as per attached specifications	1		
	<b>SUB-TOTAL</b>			
	<b>VAT</b>			
	<b>TOTAL COST</b>			
Lot 2	60 KVA Generator for Mt Selinda Border Post as per attached specifications	1		
Lot 2	250 KVA Generator for Masvingo Zimre Centre as per attached specifications	1		
	<b>SUB-TOTAL</b>			
	<b>VAT</b>			
	<b>TOTAL COST</b>			



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

Lot No	Description of Goods	Quantity <sup>2</sup>	Unit Price <sup>3</sup> US\$/ZWL\$	Total Price <sup>4</sup> US\$/ZWL\$
			[to be provided by the Bidder]	[to be provided by the Bidder]
Lot 3	500 KVA Generator for Mlahlandela as per attached specifications	1		
Lot 3	60 KVA Generator for Mphoengs Border Post as per attached specifications	1		
	<b>SUB TOTAL</b>			
	<b>VAT</b>			
	<b>TOTAL COST</b>			


Note 1: The description or quantity must indicate the unit of measure where relevant.

Note 2: Unit and total prices must be for delivery through to the final destination stated in Part 1.

Note 3: Include any additional costs, such as installation or commissioning.

Note 4: Bidders must bid for a full Lot, as the award will be made per Lot

Note 5 Acceptance testing: The Equipment will be deemed acceptable only when the Zimra Engineering Division has tested it.



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

## Delivery Schedule

Name of Bidder:

Bidder's Reference Number:

*{Note to Bidders: If the delivery period offered, or any other details, differ from the requirements below, this should be stated in your tender}.*

LOT No	Description of Goods	Quantity	Physical Unit	Delivery Date Required by Procuring Entity and applicable INCOTERM	Bidder's offered Delivery period
				6 weeks from last signature date	{to be provided by the Bidder}
Lot 1	300 KVA Generator for ZB Centre as per attached specifications.	1			
Lot 1	15 KVA Generator for Central Stores as per attached specifications	1			
Lot 1	60 KVA Generator for Kariba Border Post as per attached specifications	1			
Lot 2	60 KVA Generator for Mt Selinda Border Post as per attached specifications	1			
Lot 2	250 KVA Generator for Masvingo Zimre Centre as per attached specifications	1			
Lot 3	500 KVA Generator for Mlahlandela as per attached specifications	1			
Lot 3	60 KVA Generator for Mphoengs Border Post as per attached specifications	1			

The delivery period required is measured from the date of the signing of the Contract between the Procuring Entity and the Bidder.



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

The Project Site for delivery of all the goods is the final destination:

Stated site as per bidding document

## Technical Specification and Compliance Sheet


Name of Bidder:

Bidder's Reference Number:

*The Goods and Related Services must comply with following Technical Specifications and Standards:*

*[Columns a and b are completed by the Procuring Entity. Column c must be completed by the Bidder to indicate the full specification of the items offered and their compliance with the specification required (in Column b)]*

	A	b	c
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
1	<b>Minimum of 300KVA Prime Generator with the below features;</b>		
ZB	a) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer Switch (ATS)</li> </ul>	
CENTRE	b) Fuel System	Diesel	
	c) Fuel Tank Capacity	8hours & above	
	d) Engine Cooling Method	Water	
	e) Engine Operating speed	1500RPM	
	f) Frequency	50HZ	
	g) Alternator Output	300KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire	





# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	A	b	c
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		Frequency -- 50Hz Neutral Point Solidly Earthed	
	h) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	i) Control Panel type	<ul style="list-style-type: none"> <li>• Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>• Selectable Multifunction meter</li> <li>• Alternator voltage monitor.</li> <li>• Engine hours run counter.</li> <li>• Voltmeter and Ammeter</li> <li>• Frequency and engine speed monitor</li> </ul>	
	j) Remote Monitoring	<p>The monitoring system should be compatible with mobile phone and laptop to monitor;</p> <ul style="list-style-type: none"> <li>- Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	k) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the	



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS


PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	<b>A</b>	<b>b</b>	<b>c</b>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
<b>LOT</b>	<b>DESCRIPTION/ FEATURES</b>	<b>MINIMUM REQUIREMENTS</b>	
		existing infrastructure.	
	l) Documentation	-Full set of operation and maintenance manuals - Full set of wiring diagrams	
	m) Warranty	One year or 1000Hours	

	<b>a</b>	<b>b</b>	<b>c</b>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
<b>LOT</b>	<b>DESCRIPTION/ FEATURES</b>	<b>MINIMUM REQUIREMENTS</b>	
<b>1</b>	<b>Minimum of 15KVA Prime Generator with the below features;</b>		
<b>CENTRAL STORES</b>	n) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer Switch (ATS)</li> </ul>	
	o) Fuel System	Diesel	
	p) Fuel Tank Capacity	8hours & above	
	q) Engine Cooling Method	Water	
	r) Engine Operating speed	1500RPM	
	s) Frequency	50HZ	
	t) Alternator Output	15KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		Neutral Point Solidly Earthed	
	u) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	v) Control Panel type	<ul style="list-style-type: none"> <li>Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>Selectable Multifunction meter</li> <li>Alternator voltage monitor.</li> <li>Engine hours run counter.</li> <li>Voltmeter and Ammeter</li> <li>Frequency and engine speed monitor</li> </ul>	
	w) Remote Monitoring	<p>The monitoring system should be compatible with mobile phone and laptop to monitor;</p> <ul style="list-style-type: none"> <li>Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	x) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the	



**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

**PART 2 STATEMENT OF REQUIREMENTS**

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		existing infrastructure.	
	y) Documentation	-Full set of operation and maintenance manuals - Full set of wiring diagrams	
	z) Warranty	One year or 1000Hours	

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
1	Minimum of 60KVA Prime Generator with the below features;		
KARIBA BORDER POST	aa) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer</li> </ul>	




**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

**PART 2 STATEMENT OF REQUIREMENTS**

	<b>a</b>	<b>b</b>	<b>c</b>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
<b>LOT</b>	<b>DESCRIPTION/ FEATURES</b>	<b>MINIMUM REQUIREMENTS</b>	
		Switch (ATS)	
	bb) Fuel System	Diesel	
	cc) Fuel Tank Capacity	8hours & above	
	dd) Engine Cooling Method	Water	
	ee) Engine Operating speed	1500RPM	
	ff) Frequency	50HZ	
	gg) Alternator Output	60KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz Neutral Point Solidly Earthed	
	hh) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	ii) Control Panel type	<ul style="list-style-type: none"> <li>Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>Selectable Multifunction meter</li> <li>Alternator voltage monitor.</li> <li>Engine hours run counter.</li> <li>Voltmeter and Ammeter</li> <li>Frequency and engine speed monitor</li> </ul>	
	jj) Remote Monitoring	The monitoring system should be compatible with mobile phone and laptop to monitor;	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		<ul style="list-style-type: none"> <li>- Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	kk) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the existing infrastructure.	
	ll) Documentation	<ul style="list-style-type: none"> <li>-Full set of operation and maintenance manuals</li> <li>- Full set of wiring diagrams</li> </ul>	
	mm) Warranty	One year or 1000Hours	






# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
2  MT SELINDA BORDER POST	<b>Minimum of 60KVA Prime Generator with the below features;</b>		
	nn) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer Switch (ATS)</li> </ul>	
	oo) Fuel System	Diesel	
	pp) Fuel Tank Capacity	8hours & above	
	qq) Engine Cooling Method	Water	
	rr) Engine Operating speed	1500RPM	
	ss) Frequency	50HZ	
	tt) Alternator Output	60KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz Neutral Point Solidly Earthed	
	uu) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	vv) Control Panel type	<ul style="list-style-type: none"> <li>• Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>• Selectable Multifunction meter</li> <li>• Alternator voltage monitor.</li> </ul>	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		<ul style="list-style-type: none"> <li>• Engine hours run counter.</li> <li>• Voltmeter and Ammeter</li> <li>• Frequency and engine speed monitor</li> </ul>	
	uu) Remote Monitoring	<p>The monitoring system should be compatible with mobile phone and laptop to monitor;</p> <ul style="list-style-type: none"> <li>- Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	ww) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the existing infrastructure.	
	xx) Documentation	<ul style="list-style-type: none"> <li>- Full set of operation and maintenance manuals</li> <li>- Full set of wiring diagrams</li> </ul>	
	yy) Warranty	One year or 1000Hours	






**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

**PART 2 STATEMENT OF REQUIREMENTS**

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
<b>LOT</b>	<b>DESCRIPTION/ FEATURES</b>	<b>MINIMUM REQUIREMENTS</b>	
<b>2</b>	<b>Minimum of 250KVA Prime Generator with the below features;</b>		
<b>MASVINGO ZIMRE CENTRE</b>	zz) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer Switch (ATS)</li> </ul>	
	aaa) Fuel System	Diesel	
	bbb) Fuel Tank Capacity	8hours & above	
	ccc) Engine Cooling Method	Water	
	ddd) Engine Operating speed	1500RPM	
	eee) Frequency	50HZ	
	fff) Alternator Output	250KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz Neutral Point Solidly Earthed	
	ggg) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	hhh) Control Panel type	<ul style="list-style-type: none"> <li>• Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> </ul>	




**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 1 BIDDING PROCEDURES**

**PART 2 STATEMENT OF REQUIREMENTS**

	<i>a</i>	<i>b</i>	<i>c</i>
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
<b>LOT</b>	<b>DESCRIPTION/ FEATURES</b>	<b>MINIMUM REQUIREMENTS</b>	
		<ul style="list-style-type: none"> <li>Selectable Multifunction meter</li> <li>Alternator voltage monitor.</li> <li>Engine hours run counter.</li> <li>Voltmeter and Ammeter</li> <li>Frequency and engine speed monitor</li> </ul>	
	iii) Remote Monitoring	<p>The monitoring system should be compatible with mobile phone and laptop to monitor;</p> <ul style="list-style-type: none"> <li>Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	jjj) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the existing infrastructure.	
	kkk) Documentation	<ul style="list-style-type: none"> <li>-Full set of operation and maintenance manuals</li> <li>- Full set of wiring diagrams</li> </ul>	
	lll) Warranty	One year or 1000Hours	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
3	Minimum of 500KVA Prime Generator with the below features;		
MLAHLANDELA	mmm) Generator unit	<ul style="list-style-type: none"> <li>Diesel Generator Set</li> <li>Exhaust System</li> <li>Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>Automatic Transfer Switch (ATS)</li> </ul>	
	nnn) Fuel System	Diesel	
	ooo) Fuel Tank Capacity	8hours & above	
	ppp) Engine Cooling Method	Water	
	qqq) Engine Operating speed	1500RPM	
	rrr) Frequency	50HZ	
	sss) Alternator Output	500KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz Neutral Point Solidly Earthed	
	ttt) Battery Charging Systems	Engine alternator and Electrical automatic trickle	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		battery charging	
	uuu) Control Panel type	<ul style="list-style-type: none"> <li>Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>Selectable Multifunction meter</li> <li>Alternator voltage monitor.</li> <li>Engine hours run counter.</li> <li>Voltmeter and Ammeter</li> <li>Frequency and engine speed monitor</li> </ul>	
	vvv) Remote Monitoring	<p>The monitoring system should be compatible with mobile phone and laptop to monitor;</p> <ul style="list-style-type: none"> <li>Battery voltage, fuel level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.</li> </ul>	
	www) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the existing infrastructure.	



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS


PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
	xxx) Documentation	-Full set of operation and maintenance manuals - Full set of wiring diagrams	
	yyy) Warranty	One year or 1000Hours	

	a	b	c
	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>Item description and full technical Specification required (including applicable standards)</i>	<i>{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}</i>
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
3 MPHOENG BORDER POST	<b>Minimum of 60KVA Prime Generator with the below features;</b>		
	zzz) Generator unit	<ul style="list-style-type: none"> <li>• Diesel Generator Set</li> <li>• Exhaust System</li> <li>• Outdoor Weather Protective and Sound Attenuating Enclosure</li> <li>• Automatic Transfer Switch (ATS)</li> </ul>	
	aaaa) Fuel System	Diesel	
	bbbb) Fuel Tank Capacity	8hours & above	
	cccc) Engine Cooling	Water	




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES

PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
	Method		
	dddd) Engine Operating speed	1500RPM	
	eeee) Frequency	50HZ	
	ffff) Alternator Output	60KVA, 380 – 400 Volts Nominal System Voltage 380 V / 220 V Number of Phases 3 phase, 5 wire Frequency -- 50Hz Neutral Point Solidly Earthed	
	gggg) Battery Charging Systems	Engine alternator and Electrical automatic trickle battery charging	
	hhhh) Control Panel type	<ul style="list-style-type: none"> <li>Power wizard/deep sea with: OFF/AUTO/MANUAL and a facility for starting and stopping of the set.</li> <li>Selectable Multifunction meter</li> <li>Alternator voltage monitor.</li> <li>Engine hours run counter.</li> <li>Voltmeter and Ammeter</li> <li>Frequency and engine speed monitor</li> </ul>	
	iii) Remote Monitoring	The monitoring system should be compatible with mobile phone and laptop to monitor; <ul style="list-style-type: none"> <li>Battery voltage, fuel</li> </ul>	





# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 1 BIDDING PROCEDURES


PART 2 STATEMENT OF REQUIREMENTS

	a	b	c
	Item description and full technical Specification required (including applicable standards)	Item description and full technical Specification required (including applicable standards)	{Confirm full specification of items offered by Bidder and compliance of items to detail in column b}
LOT	DESCRIPTION/ FEATURES	MINIMUM REQUIREMENTS	
		level, start/stop status, engine temperature, generator running, Generator On load, generator fault, generator shutdown.	
	jjjj) Installation	To include cables, Accessories, generator slab/pad and connecting the generator in line with the existing infrastructure.	
	kkkk) Documentation	- Full set of operation and maintenance manuals - Full set of wiring diagrams	
	llll) Warranty	One year or 1000Hours	


The detailed technical evaluation will examine the technical specification of the items offered in column c and determine whether this meets the minimum specification in column b. Bidders must complete column c or their tender will be rejected. Bidders are required to include technical literature to positively support the details provided in column c.

## Declaration by the Accounting Officer

I declare that the procurement is based on neutral and fair technical requirements and bidder qualifications.

  
.....

08/10/2021  
.....



**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 3 CONTRACT**

## **PART 3 CONTRACT**

### **Contract Agreement**

**Procurement Reference: DOMESTIC TENDER ZIMRA NCB 40/2021**

THIS CONTRACT AGREEMENT is made the *[insert: date]* day of *[insert: month]*, *[insert: year]*.


BETWEEN

- (1) *[insert complete name of Procuring Entity]*, a *[insert description of type of legal entity, for example, an agency of the Ministry of .... of the Government of Zimbabwe, or corporation incorporated under the laws of Zimbabwe]* and having its principal place of business at *[insert full postal address of Procuring Entity]* (hereinafter called "the Procuring Entity"), and
- (2) *[insert name of Contractor]*, a corporation incorporated under the laws of *[insert: country of Contractor]* and having its principal place of business at *[insert full postal address of Contractor]* (hereinafter called "the Contractor").

WHEREAS the Procuring Entity invited Bids for certain Goods and ancillary services, viz., *[insert brief description of Goods and Services]* and has accepted a Bid by the Contractor for the supply of those Goods and Services in the sum of *[insert Contract Price in words and figures, expressed in the Contract currency]* (hereinafter called "the Contract Price").

NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:

1. In this Agreement words and expressions shall have the same meanings as are assigned to them in the General and Special Conditions of Contract referred to below.
2. The following documents shall constitute the Contract between the Procuring Entity and the Contractor, and each shall be read and construed as an integral part of the Contract:
  - (a) This Contract Agreement;
  - (b) Special Conditions of Contract;
  - (c) General Conditions of Contract;
  - (d) Technical Requirements (including Schedule of Requirements and Technical Specifications);
  - (e) The Contractor's Bid, original Price Schedules and Delivery Schedule;
  - (f) The Procuring Entity's Notification of Contract Award;
  - (g) *[Add here any other document(s)]*.
3. This Contract Agreement shall prevail over all other Contract Documents. In the event of any discrepancy or inconsistency within the Contract Documents, then the documents shall prevail in the order listed above.





**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 3 CONTRACT**

4. In consideration of the payments to be made by the Procuring Entity to the Contractor as mentioned below, the Contractor hereby agrees with the Procuring Entity to provide the Goods and Services and to remedy any defects in them in conformity with the Contract.
5. The Procuring Entity hereby agrees to pay the Contractor in consideration of the provision of the Goods and Services and the remedying of any defects in them, the Contract Price or such other sum as may become payable under the Contract at the times and in the manner prescribed by the Contract.


IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of Zimbabwe on the day, month and year indicated above.

**For and on behalf of the Procuring Entity**

Signed:	.....
Name:	
In the capacity of:	<i>[Title or other appropriate designation]</i>

**For and on behalf of the Contractor**

Signed:	.....
Name:	
In the capacity of:	<i>[Title or other appropriate designation]</i>



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 3 CONTRACT

## General Conditions of Contract


Any resulting contract is subject to the Zimbabwe General Conditions of Contract (GCC) for the Procurement of Goods (copy available on request) except where modified by the Special Conditions below.

## Special Conditions of Contract

Procurement Reference Number... NCB40/2021

The clause numbers given in the first column correspond with the relevant clause number of the General Conditions of Contract.

GCC reference	Special Conditions
GCC 7.5	<b>Eligible Countries:</b> Only Zimbabwean companies are eligible.
GCC 8.1	<b>Notices:</b> Any notice shall be sent to the following addresses: For the Procuring Entity, the address shall be as given in the Contract document and the contact shall be, 6th <b>Floor ZB Centre, Corner Kwame Nkrumah Avenue and First Street, Harare Zimbabwe.</b>  For the Contractor, the address shall be as given in the Bid and the contact shall be <i>{state name of contact}</i>
GCC 19.1	<b>Liquidated Damages:</b> Liquidated Damages in terms of section 88 of the Act shall apply. In the case of delays in the delivery of goods, the Contractor will be liable to pay damages of 0.5% of contract price per week of delay up to a maximum of 10% of contract value. If 10% is exceeded, the contract may be cancelled  <b>NB.</b> The contractor will not be charged liquidated damages when the delay in delivery or performance is beyond the contractor's control and is not caused by fault or negligence on the part of the contractor.




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 3 CONTRACT

GCC reference	Special Conditions
GCC 21.2	<p><b>Packing, Marking and Documentation:</b> The goods shall meet the following special packing requirements in addition to the general requirements stated in GCC clause 21.1</p> <p>The documents to be furnished by the Contractor are:</p> <ol style="list-style-type: none"> <li>1. A negotiable bill of lading when the goods are coming by sea</li> <li>2. An airway bill, when the goods are coming by Air</li> <li>3. A road consignment note, when the goods are coming by road</li> <li>4. Insurance certificate,</li> </ol> <p><b>Sample provision - For Goods supplied from abroad:</b></p> <p>Upon shipment, the Contractor shall notify the Procuring Entity and the insurance company in writing of the full details of the shipment. In the event of Goods sent by airfreight, the Contractor shall notify the Procuring Entity a minimum of forty-eight (48) hours ahead of dispatch, the name of the carrier, the flight number, the expected time of arrival, and the waybill number. The Contractor shall email and then send by courier the following documents to the Procuring Entity, with a copy to the insurance company:</p> <ol style="list-style-type: none"> <li>(i) one original and two copies of the Contractor's invoice, showing the Procuring Entity as the consignee; the Contract number, Goods description, quantity, unit price, and total amount. Invoices must be signed in original;</li> <li>(ii) one original and two copies of the negotiable, clean, on-board through bill of lading marked "freight prepaid" and showing Procuring Entity as the consignee and Notify Party as stated in the Contract, with delivery through to final destination as per the Schedule of Requirements and two copies of non-negotiable bill of lading, road consignment note, truck or air waybill, or multimodal transport document, marked "freight prepaid" and showing delivery through to final destination as per the Schedule of Requirements;</li> <li>(iii) two copies of the packing list identifying contents of each package;</li> <li>(iv) copy of the Insurance Certificate, showing the Procuring Entity as the beneficiary;</li> <li>(v) one original of the manufacturer's or Contractor's Warranty Certificate covering all items supplied;</li> <li>(vi) original copy of the Certificate of Inspection furnished to the Contractor by the nominated inspection agency and six copies <i>[state whether inspection is required]</i>;</li> <li>(vii) <i>[any other procurement-specific documents required for delivery/payment purposes]</i>.</li> <li>(vi) original copy of the Certificate of Inspection furnished to the Contractor by the nominated inspection agency and six copies (where inspection is required);</li> <li>(vii) <i>[other procurement-specific documents required for delivery/payment purposes]</i>.</li> </ol>




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

## PART 3 CONTRACT

GCC reference	Special Conditions
	<p><b>Sample provision - For Goods from within Zimbabwe</b></p> <p>Upon or before delivery of the Goods, the Contractor shall notify the Procuring Entity in writing and deliver the following documents to the Procuring Entity:</p> <ul style="list-style-type: none"><li>(i) one original and two copies of the Contractor's invoice, showing the Procuring Entity, the Contract number, Goods' description, quantity, unit price, and total amount. Invoices must be signed in original;</li><li>(ii) two copies of delivery note, road consignment note, truck or air waybill, or multimodal transport document showing Procuring Entity as the consignee and delivery through to final destination as stated in the Contract;</li><li>(iii) copy of the Insurance Certificate, showing the Procuring Entity as the beneficiary;</li><li>(iv) four copies of the packing list identifying contents of each package;</li><li>(v) one original of the manufacturer's or Contractor's Warranty certificate covering all items supplied;</li></ul> <p>The above documents shall be received by the Procuring Entity before arrival of the Goods and, if not received, the Contractor will be responsible for any consequent expenses.</p>




# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 3 CONTRACT

GCC reference	Special Conditions
GCC 22.1	<b>Insurance:</b> The Goods shall be insured in accordance with the specified Incoterms.
GCC 23.1 & 23.2	<b>Inspections and tests:</b> the tests and/or inspections of the Goods and Related Services that the Contractor is required to carry at its own expense are: 100% inspection on technical compliance.
GCC 24.1	<b>Performance security:</b>  After the award of the tender, and before the contract is signed; the winning bidder must furnish ZIMRA with performance guarantee within 14 days after notification of the award. This guarantee will be in the form of a Performance Bond or guarantee equivalent to the value of 10% of the total cost of the supplier's proposal, valid for the duration of the contract and endorsed by a registered reputable Commercial Bank
GCC 24.4	<b>Reduction of performance security</b> ( <i>Not applicable</i> )
GCC 25.1	<b>Warranty:</b> The period of the warranty shall be one (1) year manufacturer warranty.
GCC 25.6	<b>Failure to remedy a defect:</b> The period allowed to the Contractor to remedy a defect during the period of the Warranty shall be (30) days
GCC 29.1	<b>Price adjustments:</b> The following price adjustments are applicable.  When the application of price adjustment would modify the initial price by more than twenty per centum or would modify the balance owing under the contract by more than twenty per centum, the procuring entity may terminate the contract
GCC 30.1	<b>Terms of Payment:</b> The structure of payments shall be:  <b>Acceptance:</b> The Contract Price shall be paid to the Contractor within thirty (30) days after the date of the acceptance certificate for the respective delivery issued by the Procuring Entity.  Payment will be made to local suppliers in Zimbabwe Dollars (ZWL\$) at the prevailing RBZ Auction rate on the date of payment.  In the event that advance payment is required, the Contractor must avail a bank guarantee of the equivalent amount from a reputable registered commercial bank redeemable in Zimbabwe.
GCC 31.1	<b>Contract Administration Fee:</b> The Contract Administration Fee set out in Part VI of the Public Procurement and Disposal of Public Assets (General) (Amendment) Regulations, 2020 (No.2) is due upon the signing of the Contract and the applicable Fee ZWL\$8,000 for domestic bidders per annum.



**BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS**

**PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021**

**PART 3 CONTRACT**

## **Bank Guarantee for Performance Security**

*[This is the format for the Performance Security to be issued by a commercial bank in Zimbabwe in accordance with GCC 18.1]*

Contract No:

Date:

To:

[Name and address of Procuring Entity]

### **PERFORMANCE GUARANTEES No:**

We have been informed that *[name of supplier]* (hereinafter called "the Supplier") has undertaken, pursuant to Contract No *[reference number of Contract]* dated *[date of Contract]* (hereinafter called "the Contract") for the supply of *[description of goods and related services]* under the Contract.

Furthermore, we understand that, according to your conditions, Contracts must be supported by a performance guarantee.


At the request of the Supplier, we *[name of bank]* hereby irrevocably undertake to pay you, without cavil, delay or argument, any sum or sums not exceeding in total an amount of *[insert amount in figures and in words]* upon receipt by us of your first written demand accompanied by a written statement that the Supplier is in breach of its obligation(s) under the Contract conditions, without you needing to prove or show grounds or reasons for your demand of the sum specified therein.

This guarantee is valid until full recovery of the entire sum of money above stated, consequently, we must receive at the above-mentioned office any demand for payment under this guarantee in case of default.

Signature

Signature

--



# BIDDING DOCUMENT FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS

PROCUREMENT REFERENCE NO: DOMESTIC TENDER ZIMRA NCB 40/2021

PART 3 CONTRACT

## Bid-Securing Declaration

*{The Bidder must fill in this Form in accordance with the instructions indicated, where it has been stated in the Bidding Procedures that a Bid-Securing Declaration is a requirement of bidding}.*

Procurement Reference number:

Date: .....[date (in day, month and year format)]

Bidder's Reference Number:

To: {full name of Procuring Entity}

We, the undersigned, declare that:

We understand that, according to the terms and conditions of your bidding documents, bids must be supported by a Bid-Securing Declaration.

We accept that we may be debarred from bidding for any contract with a Procuring Entity in Zimbabwe for a period of time to be determined by the Authority, if we are in breach of our obligation(s) under the bidding conditions, because:

- (a) we have withdrawn our Bid during the period of Bid validity; or
- (b) having been notified of the acceptance of our Bid by the Procuring Entity during the period of bid validity, we fail or refuse to execute the Contract.

We understand this Bid Securing Declaration will expire if we are not the successful Bidder, either when we receive your notification to us of the name of the successful Bidder, or twenty-eight days after the expiration of our Bid, whichever is the earlier.

Signed .....

Name: .....

In capacity of: .....

Date: .....(DD/MM/YY)

Duly authorised for and on behalf of:

Company .....

Address: .....

.....

Corporate Seal (where appropriate)

*{Note: In case of a Joint Venture, the Bid Securing Declaration must be in the name of all the partners to the Joint Venture that submits the Bid.*

