

**ZIMBABWE REVENUE AUTHORITY  
COMMISSIONER GENERAL**



WRITE TO:  
THE COMMISSIONER GENERAL  
ZIMBABWE REVENUE  
AUTHORITY  
PO BOX 4360  
HARARE

TELEPHONE:  
+263-4-758891/5  
FAX:  
+263-4-707400  
TELEGRAPHS:  
HARARE

CALL AT:  
RECEPTION  
6<sup>th</sup> FLOOR ZB CENTRE  
CORNER KWAME NKRUMAH  
AVE/ FIRST STREET  
HARARE

IN REPLY PLEASE QUOTE:  
NCB 40/2021

11 November, 2021.

TO: ALL BIDDERS.

**ADDENDUM 1 TO LOT 1: ZIMRA TENDER NO NCB 40/2021 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF GENERATORS FOR ZIMRA.**

**LOT 1**

Following the site meetings held on the 22<sup>nd</sup> and 29<sup>th</sup> of October 2021 respectively. You are advised to take note of the additional information and additional provisions for the sites below.

**KARIBA**

1. Decommissioning of currently used generator, Zimra will transport.
2. Install a cable tray for cable management.
3. Install weather protection for the change over switch.
4. Cabling – 20 meters cable length (4 core x 16mm<sup>2</sup>)  
2 meters Earth wire

**CENTRAL STORES**

1. Upgrade distribution board to a 3 phase.
2. The change overswitch position is to remain the same.
3. Remove shade and put proper slab (plinth) for the generator
4. Cut tar for cable installation and make good the tar
5. Cable tray x 12 lengths
6. 4 core cable and earthwire, 45m x 10mm<sup>2</sup> cable, earthwire 45m x 10mm

**ZB CENTRE**

1. Install slab on generator position.
2. A stand alone Automatic Transfer Switch 630 Amps

3. 4 breakers of 125 Amps for the four floors which are to be excluded.
4. Provision to modify DB to suit changes to be done
5. Install cable tray
6. Control cable 12 core x 145m
7. Cable 4 core, 350m x 120mm<sup>2</sup>
8. Earthwire 145m x 120mm

Following these adjustments, the closing date for the tender is therefore pushed forward to the 29<sup>th</sup> of November 2021 to allow prospective bidders to prepare their bidding documents in relation to the new information from the site meetings.

  
T Shonhiwa (Mr.)

Director Procurement Management Unit  
ZIMRA

