

WRITE TO:
THE COMMISSIONER GENERAL
ZIMBABWE REVENUE
AUTHORITY
PO BOX 4360
HARARE

TELEPHONE: +263-4-758891/5 FAX: +263-4-707400 TELEGRAPHS: HARARE

CALL AT:
RECEPTION
6th FLOOR ZB CENTRE
CORNER KWAME NKRUMAH
AVE/ FIRST STREET
HARARE

IN REPLY PLEASE QUOTE: NCB 40/2021

11 November ,2021.

TO: ALL BIDDERS.

ADDENDUM 2 TO LOT 2: ZIMRA TENDER NO NCB 40/2021 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISIONING OF GENERATORS FOR ZIMRA.

LOT 2

Following the site meetings held on the 2nd and 3rd of November 2021. You are advised to take note of the additional information and additional provistions for the sites below.

MT SELINDA

- 1. Decommissioning of currently used generator, Zimra will transport.
- 2. 125 Amps Automatic transfer switch.
- 3. Construct a shade with plinth (Winning bidder will get design for the shade).
- 4. Cabling 30 meters cable length (4 core x 16mm2) 30 meters Earth wire (16mm2)

MASVINGO

- 1. Open type generator (no longer silent generator).
- 2. 400 Amps Automatic transfer switch to be installed in the switch room
- 3. Install cowling to take heat out (size 150cm x 100cm) (Canvas material)
- 4. Exhaust extension
- 5. Cable length 50m x 185mm2 4 core
- 6. Signal cable 5 core, 15m x1.5mm (control cable)
- 7. Earth cable 25m x 95mm2

Following these adjustments, the closing date for the tender is therefore pushed forward to the 29th of November 2021 to allow prospective bidders to prepare their bidding documents in relation to the new information from the site meetings.

T Shonhiwa (Mr.)

Director Procurement Management Unit | NOV 2021

ZIMRA

HEAD OFFICE
HOCHOS Unit | NOV 2021 003 HO

BOX 4360, HARAR