

WRITE TO:
THE COMMISSIONER GENERAL
ZIMBABWE REVENUE
AUTHORITY
PO BOX 4360
HARARE

TELEPHONE: +263-4-758891/5 FAX: +263-4-707400 TELEGRAPHS: HARARE CALL AT:

RECEPTION

6th FLOOR ZB CENTRE

CORNER KWAME NKRUMAH

AVE/ FIRST STREET

HARARE

11 November ,2021.

TO: ALL BIDDERS.

ADDENDUM 3 TO LOT 3: ZIMRA TENDER NO NCB 40/2021 FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISIONING OF GENERATORS FOR ZIMRA.

LOT 3

Following the site meetings held on the 4th and 5th of November 2021. You are advised to take note of the additional information and additional provistions for the sites below.

MHLAHLANDLELA

- 1. Put a plinth for the generator
- 2. To fabricate stand alone Automatic Transfer Switch 800Amps
- 3. Cables from the generator to run underground and use existing duct into the switch room
- 4. Cable length 100m x 185mm2
- 5. Signal cable 30meters
- 6. Earthwire 60m x 120mm2
- 7. Winning bidder will get design for the shade and will put a provision for exhaust extension

MPHOENGS

- 1. Exhaust extension
- 2. Automatic Transfer Switch to be installed on the wall, 125Amps
- 3. Cable size 20m x 25mm2
- 4. Signal cable 10m
- 5. Earthwire 10m x 16mm2

Following these adjustments, the closing date for the tender is therefore pushed forward to the 29th of November 2021 to allow prospective bidders to prepare their bidding documents in relation to the new information from the site meetings.

T Shonhiwa (Mr.)

Director Procurement Management U

ZIMRA

HEAD OFFICE

O. BOX 4360, HARARE