



**ZIMBABWE REVENUE AUTHORITY  
COMMISSIONER GENERAL**

WRITE TO:  
THE COMMISSIONER GENERAL  
ZIMBABWE REVENUE  
AUTHORITY  
PO BOX 4360  
HARARE

TELEPHONE:  
+263-4-758891/5  
FAX:  
+263-4-707400  
TELEGRAPHS:  
HARARE

CALL AT:  
RECEPTION  
6<sup>th</sup> FLOOR ZB CENTRE  
CORNER KWAME NKRUMAH  
AVE/ FIRST STREET  
HARARE

IN REPLY PLEASE QUOTE:  
NCB 15/2022

**04 April ,2022.**

**TO: ALL BIDDERS.**

**ADDENDUM NO.1 TO ZIMRA TENDER NO NCB 15/2022 FOR THE SUPPLY, DELIVERY AND INSTALLATION OF BIOMETRIC ACCESS CONTROL.**

**Query 1.**

Does ZIMRA provide switches?

**Response 1.**

No, the prospective supplier should provide switches and all the accessories that are required for the system to function.

**Query 2.**

If the prospective supplier is providing switches what brand do you recommend?

**Response 2.**

ZIMRA is not brand specific.

**Query 3.**

What systems should it integrate with?

**Response 3.**

It should integrate with CCTV System

**Query 4.**

How many cards should the system come with?

**Response 4.**

It should come with 300 cards

**Query 5.**

How many users should the system accommodate?

**Response 5.**

It should accommodate up to 3000 users

**Query 6.**

Should the system come with override key and break glass?

**Response 6.**

Yes, every door should have an override key and break glass.

**Query 7.**

What size of the magnetic lock do you require?

**Request 7.**

600 LBS

**Query 8.**

What size should a door closer be?

**Request 8.**

Standard.

All other requirements including closing date remain unchanged as per the Bidding Document.

Yours Faithfully



**T Shonhiwa (Mr.)**

**Director Procurement Management Unit  
ZIMRA**

