



**ZIMBABWE REVENUE AUTHORITY
COMMISSIONER GENERAL**

WRITE TO:
THE COMMISSIONER GENERAL
ZIMBABWE REVENUE
AUTHORITY
PO BOX 4360
HARARE

TELEPHONE:
+263-4-758891/5
FAX:
+263-4-707400
TELEGRAPHS:
HARARE

CALL AT:
RECEPTION
6th FLOOR ZB CENTRE
CORNER KWAME NKURUMAH
AVE/ FIRST STREET
HARARE

IN REPLY PLEASE QUOTE:
NCB 16/2022

04 April, 2022.

TO: ALL BIDDERS.

ADDENDUM NO.1 TO ZIMRA TENDER NO NCB 16/2022 FOR THE SUPPLY, DELIVERY AND INSTALLATION OF AN FM200 FIRE SUPPRESSION SYSTEM FOR ZIMRA DATA RECOVERY SITE.

ADDITION EQUIPMENT TECHNICAL SPECIFICATIONS (KURIMA DATA SITE)

1. Room size 9.2m X 7m X height 2.5 m.
2. Tanks 85 kg X 2.
3. The system should cover underground void.
4. Four heat and smoke detection sensors on both the ceiling and underground void.
5. The system should come with air conditioner shutdown Unit.
6. Extinguishant and Fire control panel X 1.

ADDITION EQUIPMENT TECHNICAL SPECIFICATIONS (KENSINGTON DATA SITE)

1. Room size 3.95m X 2.63m + 1.06m X 3.48m + 3.69m X 4.58m and height 2.6m.
2. Tanks 85 kg X 2.
3. The system should cover underground void.
4. Six heat and smoke detection sensors on both the ceiling and underground void.
5. The system should come with air conditioner shutdown Unit.
6. Extinguishant and Fire control panel X 1.

All other requirements including closing date remain unchanged as per the Bidding Document.

Yours Faithfully

**T Shonhiwa (Mr.)
Director Procurement Management Unit
ZIMRA**

