


WATER NOTES

- 1. Hot and cold water pipes shall be of copper to BS 2871 part 1
- with fittings connex or similar approved compression or cappilllary fittings 2. Valves for hot and cold water to be fullway gate valves to BS 1952—01956 or ball valves of
- 3. All pipes to be suitably supported by brackets or holderbatts fixed to walls, 4. Spacing of pipe supports: 18mm or less—2m; 20mm to 28mm—2.5m; 32mm to 50mm—3m.
- with canvas lagging.
- 5. Hot water pipes in ceiling space to be insulated with fibreglass and protected 6. All pipes through walls beams and slabs are to be sleeved.
 7. Sleeves shall be black steel to BS 1387 medium or PVC tube 8. Space between pipe and sleeve shall be chalked with asbestos chord 9. No joints to be embeded in walls except for showers.
 10. 25mm vent pipe from water heater to the the nearest drain



DRAINAGE NOTES

- 1 All drain pipes shall be PVC unless otherwise specified.
- 2— All drain pipes in slabs, through walls shall be sleeved to the approval of the supervising engineer.
- 3 All bends and joining branch pipes shall have an inspection eye/cover.
- 4 drain pipes shall be of PVC with the following minimum sizes:

- 5 All pipes in the ground (outside building should be laid
 - a minimum depth of 750mm below surface.
- 6 All wc's to have a short stub vent complete with cowl except specified.
- 7 All junctions and radius bends to have an inspection / access cover.
- 8 All drain pipes shall have a minimum fall of 1:60 unless otherwise specified.
- 9 Refer to Civil Engr's drawings for continuation of pipeworks
 - outside the buildings to the nearest sewer /drainage reticulation pipe work.
- 10 All installations to comply with new model building by laws.
- 11 All vent pipes to discharge to atmosphere at 300mm
 - above roof level with galvanised or copper bird guard.

Notes	AMENDMENT Lttr date Init Description:		Ministry of Local Government,	Architect M. Dube	Branch Head Eng H. Hungwe	FINANCE C	Forbes Border Post Mutare
			and Public Works	Designed K. Nyemba Drawn	Section Head D. Takaindisa	Staff Accomodation	
		F:\MLGPWNH\L@GD\Pasted 1.6mp	P.O. Box CY441, Causeway	K. Nyemba Checked E. Kwezera	Date August 2021	Water and Sewer Reticulation	
	Micro-film Drwg No		Zimbabwe	Telephone 728201/9, Fax 263 4 79	File Pef	Stock Drwg No G.P. No Proj No	192593/MECH/01