

AIR CONDITIONING NOTES

- 1 ALL CEILING CASSETTE UNITS TO BE MOUNTED AND FLASH WITH THE CEILING.
- 2 THE SPECIALIST AIR-CONDITIONING SUPPLIER & INSTALLER SHALL BE RESPONSIBLE FOR THE PROVISION OF THE ASSOCIATED CABLING FROM THE AIR-CONDITIONING CONTROL BOARD ON EACH INDIVIDUAL UNIT AND FROM THE POWER ISOLATOR TO THE AIR-CONDITIONING CONTROL BOARD.
- 3 ALL UNITS TO HAVE INDIVIDUAL START CONTROLS
- 4 ALL DIMENSIONS TO BE VERIFIED ON SITES PRIOR TO COMMENCING SETTING OUT WORKSHOP DRAWINGS OR CONSTRUCTION.
- 5 WORKSHOP DRAWINGS TO BE SUBMITTED TO THE ENGINEER FOR APPROVAL PRIOR TO ANY MANUFACTURING
- 6 ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ENGINEER'S ATTENTION IMMEDIATELY AFTER BEING NOTICED.

NOTES

AC 1
TYPE - CEILING CASSETTE UNITS
SIZE - 18 000 BTU / hr
INPUT POWER - 2.0 KW 220-240 / 50 / Ø1
INPUT CURRENT - 9 . 8 AMPS
QTY - 4

Extractor Fan Details
required duty - 300 m³/hr
flow rate - 0.15m³/s
peak power - 0.08kw

rated motor power - 0.08kw, 240V, 50Hz, Ø1

full load current - 1.45A starting current - 2.2A Qty - 4







Notes	Amendment			Descrip	otion			
	Lttr:	Init:	Date:					

MINISTRY OF LOCAL GOVERNMENT AND W. ZVEMOYO
PUBLIC WORKS
P.Bag CY7755
CAUSEWAY
HARARE

W. ZVEMOYO
Designed: W. ZVEMOYO
Checked: E KWEZERA

